

Agiunta 9: Grads d'isolaziun minimalis tar conducts da distribuziun dal stgaurdament sco er tar conducts d'aua chauda (art. 16 OEG)

(Versiun dal 1. da schaner 2021)

Diameter nominal dals bischens [DN]	polesch	tar $\lambda > 0,03$ W/mK fin $\lambda \leq 0,05$ W/mK	tar $\lambda \leq 0,03$ W/mK
10 - 15	$\frac{3}{8}$ " - $\frac{1}{2}$ "	40 mm	30 mm
20 - 32	$\frac{3}{4}$ " - $1\frac{1}{4}$ "	50 mm	40 mm
40 - 50	$1\frac{1}{2}$ " - 2"	60 mm	50 mm
65 - 80	$2\frac{1}{2}$ " - 3"	80 mm	60 mm
100 - 150	4" - 6"	100 mm	80 mm
175 - 200	7" - 8"	120 mm	80 mm